

Commissioning Record

Jobs No:	1505	Date:	20/5/22	booth reference	booth 1							
Customer Name:	Reefer Trailers	Booth Details:										
Address:	W S Storage	Model:	Spraybooth Conversion									
	Old Whieldon Road	Serial No:	STL/CON/03/22/3323									
	Stoke on Trent ST4 4JP	Dimensions:	Length:	15.5	Height:	5.5	Width:	7				
Tel No:	07784 359380	Burner Type:	comtherm ek1									
Contact:	James Jenkins	Burner Serial No:	c2515-1									
Inlet Fan:		Extract Fan:										
Size:	1000	Make:	flaktwood	Size:	1000	Make:	Flaktwoods					
Pitch Angle:	22	Overload setting:		Pitch Angle:	22	Overload setting:	26					
Motor rated current:	25.3	Motor rated current:	25.3									
Motor Size:	13.2	Motor Size:	13.2									
Spray Mode:												
Temperature(Deg)	22	Running current	Inlet	13.7a	@	35hz	Extract	17.2a	@	40htz		
Bake Mode:												
Time Set	60	Max	60	Running current	Inlet	18a	@	45hz	Extract	11.7	@	30htz
Temperature(Deg)	60											
Aqua Mode:												
Time Set	40	Max	50	Running current	Inlet	11.7a	@	30hz	Extract	13.4a	@	35htz
Temperature(Deg)	40											
Eco Mode:												
Temperature(Deg)	22	Running current	Inlet	11.8a	@	30hz	Extract	11.8a	@	30htz		
EMAC:												
Standby Time set	manual selection	Booth Clearance Time:	5 mins									
Standby Speed(Hz)	30	Booth Noise Level on Spray dBA	78									
Shutdown Time Set	n/a	Booth Light Level Lux	lights fitted by others, 650 lux									
Clearance Lights Fitted And Working	n/a	Light fan Direction, checked	n/a	light fan speed L		R						
Emergency lights fitted and tested	n/a											
Filters:												
Inlet Filter Size:		Extract Filter Size:	2m x 1m									
Quantity:	3	Quantity:	6									
Type:	stl 500	Type:	duplex									
Gas Burner:				Oil Burner:								
Gas Pressure Meter Outlet:		Oil Nozzle Size:										
Gas pressure Governer Inlet:		Oil Pressure:										
Gas pressure Governer outlet:		CO2 %		O2%		CO PPM						
CO ppm	Spray	Bake	flue Temperature (deg C):									
CO2 ppm on spray		burner efficiency %										
Gas Train Tightness Check:												
Burner Controls												
pm25 set to	100	pm25 tested	yes	O/T stat fitted	yes	adequate ventilation	yes					
Fan Speeds				Logo Parameters								
Inlet Speed												
Spray:	35hz											
Aqua:	30hz											
Bake:	45hz			MCB's								
ECO:	30hz			Sizes checked against wiring diagram								
Extract				EPA								
Extract Max Speed:	1000 / 50htz			EPA Tested:	yes	EPA Timer set at	30 secs					
Timer Setting				Drive Parameters								
Clearance:	5mins	Eco:	n/a									
Cool down:	4 mins	EMAC:	n/a									

Spraybooth Technology Limited

8 Ballingdon Hill Industrial Estate, Sudbury, Suffolk CO10 0DX

Tel: 01787 313550 FAX: 01787 314542

Email: enquires@sprayboothtechnology.co.uk

