

If Gridded Floor Extract - Check grids are correctly fitted and installed regarding the load bars.

sample length m	total length m						
1.85	1.85						
		1.20	1.30	1.60	1.60	1.15	1.25
		1.25	1.45	2.20	1.70	1.20	1.25
				extract position			
Average Air Flow (m/s):				1.43	Duct size (m)		1
Filter size (m ²):				9.44	Extract Duct velocity m/s		17.17
Airflow Volume (m ³ /hr):				48,543			
			total width m	5.1			
			sample width m	0.85			