

If Gridded Floor Extract - Check grids are correctly fitted and installed regarding the load bars.

sample length m	total length m						
1.85	1.85						
	1.30	1.55	1.50	1.40	1.50	1.20	
	1.25	1.50	2.10	1.90	1.65	1.20	
			extract position				
Average Air Flow (m/s):				1.50	Duct size (m)		1
Filter size (m ²):				9.44	Extract Duct velocity m/s		18.07
Airflow Volume (m ³ /hr):				51,091			
			total width m	5.1			
			sample width m	0.85			